



---

**west virginia department of environmental protection**

---

Division of Air Quality  
601 57<sup>th</sup> Street SE  
Charleston, WV 25304  
Phone 304/926-0475

Jim Justice, Governor  
Austin Caperton, Cabinet Secretary  
[www.dep.wv.gov](http://www.dep.wv.gov)

February 6, 2017

Edward Valverde  
Columbia Gas Transmission, LLC  
485 Industrial Road  
Saint Albans, WV 25177

RE: Approved Registration G65-C564  
St. Albans Area Office  
Plant ID No. 039-00476

Dear Mr. Valverde:

The Director has determined that the submitted Registration Application and construction and operation of an emergency generator demonstrates eligibility and compliance with the requirements, provisions, standards and conditions of General Permit G65-C and hereby grants General Permit registration authorizing the proposed activity.

Please be aware of the actions required in Section 2.18 (Notification Requirements), Section 4.2 (Recordkeeping Requirements), and Section 3.5.5 (Air Quality Management Fee Program and Certificate to Operate).

Should you have any questions, please contact the undersigned engineer at (304)926-0499 ext. 1211.

Sincerely,

William T. Rothwell II, P.E.  
Engineer

Enclosures: General Permit Registration G65-C564  
General Permit G65-C

*West Virginia Department of Environmental Protection*  
*Jim Justice*  
*Governor*

*Division of Air Quality*

*Austin Caperton*  
*Cabinet Secretary*

## Class I General Permit G65-C Registration to Construct




for the  
Prevention and Control of Air Pollution in regard to the  
Construction, Modification, Relocation, Administrative Update and  
Operation of Emergency Generators

*The permittee identified at the facility listed below is authorized to  
construct the stationary sources of air pollutants identified herein in accordance  
with all terms and conditions of General Permit G65-C.*

**G65-C564**

Issued to:  
**Columbia Gas Transmission, LLC**  
**St. Albans Area Office**  
**039-00476**

  
\_\_\_\_\_  
*William F. Durham*  
Director

*Issued: February 6, 2017 • Effective: February 6, 2017*

Facility Location: Saint Albans, Kanawha County, West Virginia  
Mailing Address: 485 Industrial Road, Saint Albans, WV 25177  
Facility Description: Emergency Generator  
SIC Codes: 4922  
UTM Coordinates: 425.20 km Easting • 2015.01 km Northing • Zone 17  
Registration Type: Construction  
Description of Change: Construction of an Emergency Generator

Subject to 40CFR60 Subpart IIII? **Yes**    Certified? **Yes**  
Subject to 40CFR60 Subpart JJJJ? **No**

*Any person whose interest may be affected, including, but not necessarily limited to, the applicant and any person who participated in the public comment process, by a permit or registration issued, modified or denied by the Secretary may appeal such action of the Secretary to the Air Quality Board pursuant to article one [§§ 22B-1-1 et seq.], Chapter 22B of the Code of West Virginia. West Virginia Code §22-5-14.*

---

*The source is not subject to 45CSR30.*

---

**All registered facilities under Class I General Permit G65-C are subject to Sections 1.0, 2.0, 3.0, and 4.0.**

The following sections of Class I General Permit G65-C apply to the registrant:

Section 5	Reciprocating Internal Combustion Engines (R.I.C.E.)	<input checked="" type="checkbox"/>
Section 6	Tanks	<input type="checkbox"/>
Section 7	Standards of Performance for Stationary Compression Ignition Internal Combustion Engines (40CFR60 Subpart IIII)	<input checked="" type="checkbox"/>
Section 8	Standards of Performance for Stationary Spark Ignition Internal Combustion Engines (40CFR60 Subpart JJJJ)	<input type="checkbox"/>

### Emission Units

Emission Unit ID	Emission Unit Description (Make, Model, Serial No.)	Year Installed	Design Capacity (Bhp/rpm)
G2	Cummins QSX15-G9	2017	755 bhp / 1800 rpm

### Emission Limitations

Source ID#	Nitrogen Oxides		Carbon Monoxide	
	lb/hr	ton/yr	lb/hr	ton/yr
G2	5.15	1.29	0.67	0.17